



# Test Report Summary

Product Information	
Licence Number:	214451
Licensee:	ACOME
Product Identification	523420
Test Specifications	
Tested Application:	Water Floor Heating Systems
Temperature Sensor	
- Type:	
- Time Constant:	
Actuator Identification	523235
- Type:	Thermal: PWM
Valve Identification	THERMACOME
- Characteristic	2-way/3-way drive(23WV): linear(L)
AV Acronym	
Fan Speed (For Fan Coil Applications)	
- Characteristic	None
Test Result	
Temperature Control Accuracy $C_A$ according EN 15500	0.6

05 March 2015

Brussels

A handwritten signature in black ink, appearing to read "Peter Hug".

Managing Director Dr. Peter Hug

eu.bac